

SUBMITTAL - 36,000BTU CASED COIL - B CABINET

Job Name: _____

Location: _____

Engineer: _____

Submitted By: _____

Submitted To: _____

Submitted For: _____

Reference **Approval**

Date: _____

Unit Tag: _____

Drawing No.: _____

Construction

WARRANTY

Standard 10 Years Parts & Compressor

Terms & Conditions Apply.

TYPE

Air Source Heat Pump

Cold Climate Air Source Heat Pump

MODELS

Indoor CUB36HAC20BWT7A

Outdoor DMA36HOS20230E7

CAPACITY RANGE¹

Output (Btu/h)	Min.	Rated	Max.
Cooling	11700	36000	40000
Heating	9200	38000	45000

HEATING PERFORMANCE²

Output (Btu/h)	Min.	Rated	Max.
47°F (8.3°C)	9200	38000	45000
17°F (-8.3°C)	8900	27400	38000
5°F (-15°C)	8000	31600	31600
-22°F (-30°C)	6950		20000

OUTDOOR TEMPERATURE OPERATING RANGE

Cooling	-15 ~ 50 °C	5 ~ 122 °F
Heating ³	-30 ~ 24 °C	-22 ~ 75 °F

LINE SET & REFRIGERANT

Liquid (in.)	3/8"	Gas (in.)	3/4"
Connection Type	Flared		
Pre-Charge Length (ft)	25		
Max. Length (ft)	213.25		
Max. Height Difference (ft)	98.42		
Refrigerant Type	R410A		
Pre-Charge (oz)	165.7878		
Additional Charge per Foot (oz)	0.69		
Oil Type	VG74	Oil Volume (ml)	1460
Drain Connection (inches)	3/4"		



Images for reference only.

CERTIFIED

AHRI NO.	
212928556	

EFFICIENCY RATINGS

SEER2	15.5			
EER2	10			
HSPF2 (4)	8.6			
HSPF2 (5)	7			
COP ²	47°F (8.3°C)	17°F (-8.3°C)	5°F (-15°C)	-22°F (-30°C)
	3.18	2.12	1.85	1.26

ELECTRICAL

Power Supply	(V/Ph/Hz)	208-230/1/60		
Voltage Range	(V)	187-253		
MCA (A)	30	Max Fuse (ODU) (A)	50	
Power Input (W)	Min.	Rated	Max.	
	Cooling	800	3500	5000
Heating	800	3600	5000	
Current (A)	Min.	Rated	Max.	
	Cooling	3.5	14.8	21
Heating	3.5	15.65	21	

1. Cooling Capacity Conditions: Indoor Temperature @ 80°F (26.7°C) DB; 67°F (19.4°C) WB with Outdoor Temperature @ 95°F (35°C) DB; 75°F (23.9°C) WB. Heating Capacity Conditions: Indoor Temperature @ 70°F (21.1°C) DB; 60°F (15.6°C) WB with Outdoor Temperature @ 47°F (8.3°C) DB; 43°F (6.1°C) WB. Line Set @ 25ft (7.5m); Height Difference @ 0ft (0m). 2. COP for all temperatures is @ rated output except when rated output is not given. In that case, COP is @ max. output. 3. System continues to operate below rated outdoor temperature operating range, subject to varying conditions. System has no low temperature cutout. Capacity is not tested outside of the rated temperature range. | Cased coil unit has a continuous operating temperature limit of 248°F (120°C); this product is not recommended for applications where there is a risk of exceeding this limit (such as with an oil furnace). It is the installer's responsibility to ensure the installation respects this temperature limit. Master Group is not responsible for the accuracy and validity of any changes made to this document without the written authorization of Master Group. Specifications subject to change without notice.

DIMENSIONS & WEIGHTS

Indoor	Net (WxDxH; in.)	17.52x20.98x23.58	
	Gross (WxDxH; in.)	20.47x26.18x25.39	
	Net Weight lbs kg	60.19	27.3
	Gross Weight lbs kg	69	31.3
Outdoor	Net (WxDxH; in.)	37.48x16.34x52.48	
	Gross (WxDxH; in.)	43.11x19.49x58.27	
	Net Weight lbs kg	227.07	103
	Gross Weight lbs kg	255.73	116


KEY FEATURES

Rotary Inverter Compressor	<input checked="" type="checkbox"/>
Twin Rotary Inverter Compressor	<input type="checkbox"/>
Base Pan Heater	<input checked="" type="checkbox"/>
Crankcase Heater	<input checked="" type="checkbox"/>

INCLUDED ACCESSORIES

Adaptor for welding(3/8")
Adaptor for welding(3/4")


INDOOR UNIT DRAWING




Tag	A	B	C	D	E	F	G	H	I
inches	23-1/2	17-1/2	16-3/16	15-1/8	21	18-5/8	18	5/8	1-3/4
mm	599	445	411	384	533	473	458	16	45
Tag	J	K	L	M	N				
inches	1-3/16	1-13/16	1-7/16	16-1/2	3/4				
mm	30	46	37	418	19				

Drawing dimensions are nominal. Specifications subject to change without notice. 4. Connection of these accessories may require secondary items not listed; refer to full product literature.

OUTDOOR UNIT DRAWING



OUTDOOR UNIT CLEARANCES



Note: Outdoor units must be elevated 12-24in. (30.5-61cm) above the surface below in heating applications to allow for snow clearance and defrost runoff. Follow local best-practices and guidelines.

Diagrams for reference only.

NOTES